

## STATE BUILDING CODE INTERPRETATION NO. 99-12

**CODE:** 1997 Washington State Energy Code (WSEC), Nonresidential

**SECTION:** 1322 Opaque Envelope, Tables 13-1 and 13-2

**QUESTION:** For nonresidential structures, can a builder install the nominal R-values from Tables 13-1 and 13-2 in metal framed buildings for compliance with the prescriptive path?

**ANSWER:** Yes.

**SUPERSEDES:** None (See also Interpretation No.98-14, Residential)

**REQUESTED BY:** Department of Labor and Industries