



Washington State Building Code Council

Improving the built environment by promoting health, safety and welfare

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504
(360) 407-9277 • e-mail sbcc@des.wa.gov • www.sbcc.wa.gov

STATE BUILDING CODE INTERPRETATION NO 18-14

CODE: 2015 International Fire Code

SECTION: WAC 51-50-007

QUESTION: Does WAC 51-50-007 Exception eliminate the fire flow requirements of the IFC 2015 edition, as adopted by the State Building Code?

ANSWER: Yes.

Fire-flow requirements are exempt for the purpose of this code if the greenhouse falls under the definition of a temporary growing structure.

SUPERSEDES: None

REQUESTED BY: Benton County